





Pressure test report


Date: 13.5	Production standard:	Report no.: 1.
Project:	Tested acc. to:	
Buyer: Fjardabyggð	Test method: Vata	What tested: Löndurur
Project no.:	Test pressure: 10 bar	Lögn frá tank
Supervisor: HJ	Weather: Lopp og skíð	60 afþreiddubrun
Inspector:	Contact:	

Time	Meter 1	Meter 2	Temp°C
09.43	10,4 bar	10,5 bar	3°
10.35	10,3 bar	10,4 bar	2°
11.45	10,3 bar	10,4 bar	3°
12.45	10,3 bar	10,4 bar	5°
13.15	10,3 bar	10,4 bar	5°
13.53	10,2 bar	10,4 bar	6°

Att.: 10. mars 2021


 UMHVERFISSTOFNUN
 Mengunarvagnæftirlit
Eiríkur M.


 Inspector signing


 Supervisor signing